



## NOTES

- 1- ALL DIMENSIONS ARE IN MILLIMETERS.
- 2- CABLES SHALL BE INSTALLED IN LEVEL WITH THE ASSOCIATED PVC PIPES.
- 3- FOR CABLE ROUTE MARKER, REFER TO DWG. IPS-D-EL-208
- 4- EACH DUCT END SHALL BE REAMED.
- 5- EACH END OF THE SPARE PVC PIPE SHALL BE CAPPED.
- 6- 20% SPARE PVC PIPE SHALL BE PROVIDED.

No.	DESCRIPTION	QTY.
1		
2		
3		
4		

REV	DESCRIPTION	DATE
C		
B		
A		

IRANIAN PETROLEUM STANDARDS 

NO REVISION PERMITTED UNLESS APPROVED BY STANDARD ORGANIZATION

REFERENCE DRAWING  
POWER INSTALLATION DETAILS  
"CATEGORY 200"  
CONCRETE CABLE DUCT BANK (ROAD CROSSING)

DATE	DRAWING No.	SHEET	REV.
	IPS-D-EL-209	1	1